
TYPICAL DRAWING
VPL HOISTWAY
ADJ/90° EXIT PLATFORM

REVISIONS				
REV.	DESCRIPTION	BY	CHK	DATE
A	INITIAL RELEASE, ECO-005013	CJP	DN	16APR20



PRODUCT SPECIFICATIONS

RATED LOAD:	750 LBS (340 KG) MAXIMUM
INPUT POWER SOURCE:	
-AC POWERED UNIT:	110-120 VAC, 20 AMP, 60 HZ DEDICATED SERVICE
-OPT BATTERY BACKUP UNIT:	BASE 2X 12 V BATTERIES (NOT AVAILABLE FOR VPL800-1400) PLUS 4X 12 V BATTERIES
DRIVE:	
-AC POWERED UNIT:	2/3 HP, 26:1 GEARMOTOR W/BRAKE, 90 VDC, INTERMITTENT DUTY, CLASS H
DRIVE:	1" DIAMETER, 0.1" PITCH, 10 START ACME SCREW (1" LEAD)
LIFT SPEED:	7-10 FEET/MINUTE
SAFETY:	MOTOR FRICTION BRAKE AND ELECTRIC BRAKE, OVERSPEED GOVERNOR, BACKUP ACME NUT, SAFETY PAN, E-STOP, OVERLOAD SENSING, OVER TEMPERATURE SENSING, PERFORMANCE MONITORING, BATTERY MONITORING (ON BATTERY BACKUP UNITS)

FOR COMPLETE TECHNICAL SPECIFICATIONS, REFER TO HARMAR DOCUMENT MKT-000126.

SPECIFICATIONS SUBJECT TO CHANGE WITH OR WITHOUT NOTICE.

DESIGN AND REGULATORY REQUIREMENTS

USA FOOD & DRUG ADMINISTRATION: CLASS II, 510(K) EXEMPT FILE NO. 890.3930, PRODUCT CODE: PCE

DESIGNED IN COMPLIANCE WITH THE FOLLOWING CODES:
- ASME A18.1 SAFETY STANDARD FOR PLATFORM LIFTS AND STAIRWAY CHAIRLIFTS (SECTIONS 2 AND 5)
- CSA B44.1/ASME A17.5 ELEVATOR AND ESCALATOR ELECTRICAL EQUIPMENT
- ICC ANSI A117.1 ACCESSIBLE AND USABLE BUILDINGS AND FACILITIES
- NFPA 70 NATIONAL FIRE PROTECTION AGENCY - NATIONAL ELECTRICAL CODE
- ETL CERTIFIED - CONTROL NUMBER 3148125

FDA INDICATION OF USE STATEMENT

THE HIGHLANDER II VERTICAL PLATFORM LIFT IS TO ASSIST IN THE TRANSFER OF PATIENTS OR A MOBILITY IMPAIRED PERSON, UP AND DOWN BETWEEN LEVELS OF A RESIDENTIAL OR COMMERCIAL FACILTIY.

CONFIDENTIAL INFORMATION
NOT TO BE COPIED OR USED
WITHOUT WRITTEN CONSENT.
INTERPET DRAWING AND TOL
PER ASEM Y14.5 - 2009

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES ARE:

DECIMALS .X = ±0.1
.XX = ±0.02
.XXX = ±0.010

HOLE DIA'S = ±.005

ANGLES = ±1°

DO NOT MEASURE FROM DRAWING

Harmar

DWG NO. ENG-000845 REV A


DESCRIPTION: TYPICAL DRAWING VPL HOISTWAY ADJ/90° EXIT PLATFORM


DRAWN BY	DATE
C POLSTER	17FEB20

SCALE NTS | SIZE: B | SHEET 1 OF 4

TYPICAL DRAWING
VPL HOISTWAY
ADJ/90° EXIT PLATFORM

REVISIONS				
REV.	DESCRIPTION	BY	CHK	DATE
-	See Sheet1	-	-	-





TOWER DIMENSIONS TABLE			
LIF MODEL	A	B	C
VPL400	77	53	95
VPL600	101	77	119
VPL800	125	101	143
VPL1000	149	125	167
VPL1200	173	149	191
VPL1400	197	171	213

PLATFORM AND HOISTWAY DIMENSIONS TABLE					
PLATFORM	D	E	F	G	H
36" X 54"	36.00	54.00	54.78	9.60	33.33
36" X 60"	36.00	62.00	54.78	13.60	36.33
42" X 54"	42.00	54.00	60.78	9.60	33.33
42" X 60"	42.00	62.00	60.78	13.60	36.33

CONFIDENTIAL INFORMATION
NOT TO BE COPIED OR USED
WITHOUT WRITTEN CONSENT.
INTERPET DRAWING AND TOL
PER ASEM Y14.5 - 2009

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES.
TOLERANCES ARE:

DECIMALS .X = ±0.1
.XX = ±0.02
.XXX = ±0.010

HOLE DIA'S = ±.005

ANGLES = ±1°

DO NOT MEASURE FROM DRAWING

Harmar

DWG NO. ENG-000845

REV A


DESCRIPTION
TYPICAL DRAWING VPL HOISTWAY
ADJ/90° EXIT PLATFORM

DRAWN BY	DATE
C POLSTER	17FEB20


SCALE NTS | SIZE: B | SHEET 2 OF 4

TYPICAL DRAWING
VPL HOISTWAY
ADJ/90° EXIT PLATFORM


REVISIONS				
REV.	DESCRIPTION	BY	CHK	DATE
-	See Sheet1	-	-	-




PAD DETAILS



PIT DETAILS



SECTION A-A
THROUGH CONCRETE ANCHOR
(NOT TO SCALE)



SECTION B-B
THROUGH CONCRETE ANCHOR
(NOT TO SCALE)

	HOISTWAY DIMENSIONS		
PLATFORM	J	K	L
36" X 54"	58.37-58.75	56.37-57.75	9.00
36" X 60"	58.37-58.75	64.37-65.75	12.00
42" X 54"	62.37-62.75	56.37-57.75	9.00
42" X 60"	62.37-62.75	64.37-65.75	12.00

CONFIDENTIAL INFORMATION
NOT TO BE COPIED OR USED
WITHOUT WRITTEN CONSENT.
INTERPET DRAWING AND TOL
PER ASEM Y14.5 - 2009

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES ARE:

DECIMALS .X = ±0.1
.XX = ±0.02
.XXX = ±0.010

HOLE DIA'S = ±0.005

ANGLES = ±1°

DO NOT MEASURE FROM DRAWING

Harmar

DWG NO. ENG-000845

REV A


DESCRIPTION
TYPICAL DRAWING VPL HOISTWAY
ADJ/90° EXIT PLATFORM

DRAWN BY	DATE
C POLSTER	17FEB20


SCALE NTS | SIZE: B | SHEET 3 OF 4

TYPICAL DRAWING
VPL HOISTWAY
ADJ/90° EXIT PLATFORM

REVISIONS				
REV.	DESCRIPTION	BY	CHK	DATE
-	See Sheet1	-	-	-



TOWER SUPPORT THROUGH UPPER CROSS BRACING



TOWER SUPPORT FROM SIDE OF TOWER TO HOISTWAY

Site Construction Details

Electrical Requirements:
Refer to NFPA 70 and all applicable codes for all electrical and wiring requirements.

Platform Pathway Requirements:
Ensure the platform pathway is sufficiently illuminated, clear of any electrical conduit and wireways and there is sufficient headroom clearance (minimum of 79"-2007mm) per ASME A18.1throughout floor-to-floor travel.

Floor Recommendations:
A 4" (102mm) thick, 3500 PSI minimum compressive strength, reinforced concrete pad is recommended.

Tower Floor Anchoring:
VPL must be fastened to concrete pad using a minimum of four (4) 3/8" (5/16" bolt) x minimum 2-1/2" long concrete anchors suiltable for the environment. Refer to Pad Details on sheet 3 for mounting hole locations. Follow selected concrete anchor manufacturer's guidelines and all applicable codes.

Tower Support:
Tower support is not required on lifts with travel under 8 feet. Lifts with travel of 8 feet or more are required to be supported appropriately. See views at left or installation manual for more details.

Top Landing Gate Attachment:
Refer to landing gate detail pages.

Platform to Top of Landing Sill Clearance:
ASME A18.1 code stipulates the platform-to-sill clearance at the upper landing shall not be less than 3/8" (9.5mm) nor exceed 3/4" (19.1mm). Follow all applicable codes.

Hoistway Wall Requirements:
ASME A18.1 code stipulates that fascia should be smooth and/or non-perforated that guards the full length and width of the platform. Follow all applicable codes.

CONFIDENTIAL INFORMATION
NOT TO BE COPIED OR USED
WITHOUT WRITTEN CONSENT.
INTERPET DRAWING AND TOL
PER ASEM Y14.5 - 2009

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES ARE:

DECIMALS .X = ±0.1
.XX = ±0.02
.XXX = ±0.010

HOLE DIA'S = ±.005

ANGLES = ±1°

DO NOT MEASURE FROM DRAWING

Harmar

DWG NO. ENG-000845 REV A

DESCRIPTION
TYPICAL DRAWING VPL HOISTWAY
ADJ/90° EXIT PLATFORM

DRAWN BY	DATE
C POLSTER	17FEB20

SCALE NTS | SIZE: B | SHEET 4 OF 4